

CI/SfB

(47) Nh2

Ensor Building Products

Blackamoor Road
Guide
Blackburn
Lancashire BB1 2LQ



Agrément Certificate
No 07/4416

ROSER LIGHTWEIGHT ROOFING SYSTEM

PRODUCT SHEET 1 — ROWOOD

PRODUCT SCOPE AND SUMMARY OF CERTIFICATE

This Certificate relates to Rowood, an aggregate-coated metal tilesheet for use on conventional steel or timber structures with a minimum roof pitch angle of 12°.

THIS CERTIFICATE INCLUDES:

- factors relating to compliance with UK Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.



KEY FACTORS ASSESSED

Weathertightness — the product, with a suitable roof tile underlay, has satisfactory resistance to the passage of rain and snow.

Strength and stability — the product has satisfactory resistance to the effects of wind loading likely to be met in service.

Performance in relation to fire — the product may achieve an EXT.S.AA fire roof rating to BS 476-3 : 2004, and may, therefore, be unrestricted under the national Building Regulations.

Durability — under normal conditions the product will have an ultimate life in excess of 40 years.

The BBA has awarded this Agrément Certificate for Rowood to Ensor Building Products Limited as fit for its intended use provided it is installed, used and maintained as set out in this Agrément Certificate.

On behalf of the British Board of Agrément

Date of First issue: 29 June 2007

Greg Cooper: Chief Executive

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément
Bucknalls Lane
Garston, Watford
Herts WD25 9BA

©2007

tel: 01923 665300
fax: 01923 665301
e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk

Ensor Building Products

Blackamoor Road
Guide
Blackburn
Lancashire BB1 2LQ



Agrément Certificate
No 07/4416

ROSER LIGHTWEIGHT ROOFING SYSTEM

PRODUCT SHEET 2 — SPANY

PRODUCT SCOPE AND SUMMARY OF CERTIFICATE

This Certificate relates to Spany, an aggregate-coated metal tilesheet for use on conventional steel or timber structures with a minimum roof pitch angle of 12°.

THIS CERTIFICATE INCLUDES:

- factors relating to compliance with UK Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.



KEY FACTORS ASSESSED

Weathertightness — the product, with a suitable roof tile underlay, has satisfactory resistance to the passage of rain and snow.

Strength and stability — the product has satisfactory resistance to the effects of wind loading likely to be met in service.

Performance in relation to fire — the product may achieve an EXT.S.AA fire roof rating to BS 476-3 : 2004, and may, therefore, be unrestricted under the national Building Regulations.

Durability — under normal conditions the product will have an ultimate life in excess of 40 years.

The BBA has awarded this Agrément Certificate for Spany to Ensor Building Products Limited as fit for its intended use provided it is installed, used and maintained as set out in this Agrément Certificate.

On behalf of the British Board of Agrément

Date of First issue: 29 June 2007

Greg Cooper: Chief Executive

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément
Bucknalls Lane
Garston, Watford
Herts WD25 9BA

©2007

tel: 01923 665300
fax: 01923 665301
e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk